

CERTIFICATE OF COMPLIANCE

Certificate Number: SGSNA/24/GZ/00177

Contract Number: 802803
Certificate Project Number: GZ-CERT220902697

Certified Product: ESS Inverter

Trademarks:

Model(s): Meter Home 5KHB-130-D2/UL, Meter Home 6KHB-130-D2/UL,
Meter Home 7K6HB-180-T2/UL, Meter Home 10KHB-210-D2/UL,
Meter Home 11.4KHB-210-D2/UL

Technical Data: See Page 2-3

Certificate Holder: Meter Home
9975 SW Herman Rd, Tualatin, OR 97062, United States of America

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at www.sgs.com or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:

UL 1741, Third Edition, Dated September 28, 2021 (including UL 1741 Supplement SB)

CSA C22.2 No. 107.1:16 (reaffirmed 2021)

Photovoltaic (PV) DC Arc-Fault Circuit Protection-UL 1699B: REVISION, DATED MAY 18, 2021

CSA C22.2 No. 330:23, Dated February 2023

Authorized by:

Effective date: 09 July 2024

Jason Wei
Certifier



Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com



CERTIFICATE OF COMPLIANCE

Certificate Number: SGSNA/24/GZ/00177

Contract Number: 802803
Certificate Project Number: GZ-CERT220902697

Additional Information:

Compliance with IEEE Std 1547:2018 (Revision of IEEE Std 1547:2003), approved 15 February 2018; IEEE Std 1547a™-2020 Approved 9 March 2020. (Refer to IEEE Std 1547.1:2020, approved 5 March 2020.)

Hawaiian Electric Companies, IEEE 1547.1-2020 Source Requirements Document Version 2.0 (“SRD V2.0”), effective on July 1st, 2020

UL1741 SECTION 92 TO SECTION 99, SEPTEMBER 28, 2021 - PHOTOVOLTAIC RAPID SHUTDOWN SYSTEMS

UL1741 CRD Non-Isolated EPS Interactive PV Inverters Rated Less Than 30Kva (Dated April 26, 2010)

Technical Data: Meter Home 5KHB-130-D2/UL
 PV Input side: 70-540Vd.c(600Vmax), 30/22Amax;
 Batteries side: 40-64Vd.c, 210/130Amax (Charge/Discharge)
 AC output (On grid): 120/240Va.c (Split phase)/208Va.c(2/3 phase),
 20.9A(22.9Amax), 60Hz, 5kW, -0.8~+0.8
 AC output (Off grid): 120/240Va.c (Split phase)/
 208Va.c(2/3 phase), 5.0kW, 60Hz

Meter Home 6KHB-130-D2/UL
 PV Input side: 70-540Vd.c(600Vd.cmax), 30/22Amax;
 Batteries side: 40-64Vd.c, 210/130Amax(Charge/Discharge)
 AC output (On grid): 120/240Va.c (Split phase)/ 208Va.c(2/3phase),
 25A(27.5Amax), 60Hz, 6kW, -0.8~+0.8
 AC output (Off grid): 120/240Va.c (Split phase)/
 208Va.c(2/3 phase), 6.0kW, 60Hz

Certification Body

Connectivity & Products, a division of SGS North America Inc.
 620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
 t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

CERTIFICATE OF COMPLIANCE

Certificate Number: **SGSNA/24/GZ/00177**

Contract Number: 802803

Certificate Project Number: GZ-CERT220902697

Technical Data: Meter Home 7K6HB-180-T2/UL

PV Input side: 70-540Vd.c(600Vd.cmax), 30/22/22Amax;

Batteries side: 40-64Vd.c, 210/180Amax(Charge/Discharge)

AC output (On grid): 120/240Va.c (Split phase)/208Va.c(2/3 phase),
31.7A(34.8Amax), 60Hz, 7.6kW, -0.8~+0.8

AC output (Off grid): 120/240Va.c (Split phase)/
208Va.c(2/3 phase), 7.6kW,60Hz

Meter Home 10KHB-210-D2/UL

PV Input side: 70-540Vd.c(600Vd.cmax), 30/22/22Amax;

Batteries side: 40-64Vd.c, 210/210Amax(Charge/Discharge)

AC output (On grid): 120/240Va.c (Split phase)/ 208Va.c(2/3phase),
41.7A(45.8Amax), 60Hz,10kW, -0.8~+0.8

AC output (Off grid): 120/240Va.c (Split phase)/
208Va.c(2/3 phase), 10kW, 60Hz

Meter Home 11.4KHB-210-D2/UL

PV Input side: 70-540Vd.c(600Vd.cmax), 30/22/22Amax;

Batteries side: 40-64Vd.c, 210/210Amax(Charge/Discharge)

AC output (On grid): 120/240Va.c (Split phase)/ 208Va.c(2/3phase),
41.7A(47.5Amax), 60Hz,10kW, -0.8~+0.8

AC output (Off grid): 120/240Va.c (Split phase)/
208Va.c(2/3 phase), 10kW, 60Hz

Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com